



BUILDING CODE COMPLIANCE OFFICE
MIAMI DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901
FAX (305) 375-2908

PRODUCT CONTROL SECTION
(305) 375-2902
FAX (305) 372-6339

MEMO

TO: All Building Officials in Miami-Dade County

**FROM: Francisco J. Quintana, R.A., Director
Building Code Compliance Office**

DATE: April 8, 2002

SUBJECT: Flamebar B. W. 11 Fire Resistant Ductwork

At its March 21, 2002 meeting, the Board of Rules and Appeals (BORA) accepted the use of Flamebar B. W. 11 Fire Resistant Ductwork as an "equal alternate" to the requirements of horizontal shaft enclosures, as specified in the South Florida Building Code, Section 1807.

The board ruled unanimously to approve the use of this product as long as it was installed according to the products manufacturer's listing.

If you have any questions regarding this information, please feel free to call Mr. Pete Quintela at 305-375-2901.



W:\Building Officials\020408 Flamebar B.W..doc

Internet mail address:
Postmaster@buildingcodeonline.com



Homepage:
<http://www.buildingcodeonline.com>