



+

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING**

**BUILDING CODE COMPLIANCE OFFICE**  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305)375-2908


**CONTRACTOR LICENSING SECTION**  
(305) 375-2527 FAX (305) 375-2558

**CONTRACTOR ENFORCEMENT SECTION**  
(305) 375-2966 FAX (305) 375-2908

**PRODUCT CONTROL DIVISION**  
(305) 375-2902 FAX (305) 372-6339

## MEMO

**TO: All Building Officials in Miami-Dade County**

**FROM:** *fn*  **Herminio F. González, P.E., M.S., Director  
Building Code Compliance Office**

**DATE: December 10<sup>th</sup>, 2009**

**SUBJECT: Removal of NOA 07-0928.04**

---

Please be advised that American Slate's NOA No. 07-0928.04 has been removed due to improper nail-hole placement on the slate. American Slate has filed for a substitute NOA, which will appear on our website as soon as it is approved. You can confirm acceptance of this or any other NOA at [www.miamidade.gov/buildingcode](http://www.miamidade.gov/buildingcode) and click on 'Approved Product Search'.

If you have any questions, please contact Mr. Jaime Gascon, P.E. of my staff at (305) 375-2902.