



MEMO

TO: All Building Officials in Miami-Dade County

FROM: Michael L. Goolsby, Director *WLG*
Board and Code Administration Division

DATE: October 19, 2012

SUBJECT: Notice of NOA Removal – Zion Tile Corporation NOA #07-0815.03

This is to inform you of the removal of Zion Tile Corporation's NOA effective October 19, 2012 due to the roofing tile not complying with the required thickness and breaking strength specifications. The tiles bear the marking "Zion Tile Corp. Made in Nicaragua".

If you have any questions or need additional information, please contact Jaime Gascon, P.E., Product Control Section Supervisor at 786-315-2590.

Thank you for your attention on this matter.