



Department of Regulatory and Economic Resources
Product Control Section
11805 S.W. 26 Street (Coral Way) • Room 208
Miami, Florida 33175-2474
T 786 -315-2590 F 786-315-2599

miamidade.gov

MEMO

TO: All Building Officials in Miami-Dade County

FROM: Michael L. Goolsby, Director *MLG*
Board and Code Administration Division

DATE: May 10, 2013

SUBJECT: Notice of NOA Removal
Masterpiece Tile Company, Inc. - NOA #09-0505.04

The Masterpiece Tile Company's NOA has been removed effective May 10, 2013 due to the roofing tile not complying with the required breaking strength and fabricator specifications. The roofing tiles bear the marking "Santa Ana" on the topside of the tile just above the nail hole.

If you have any questions or need additional information, please contact Jaime Gascon, P.E., Product Control Section Supervisor at 786-315-2590.

Thank you for your attention on this matter.