



MEMO

TO: All Building Officials in Miami-Dade County

FROM: Jaime Gascon, Assistant Director 
Board and Code Administration Division

DATE: June 22, 2020

SUBJECT: Notice of NOA Removals

17-0615.03 Eco Window Systems, LLC

18-0129.14 Eco Window Systems, LLC

This is to inform you of the removal of the referenced NOAs as of May 29, 2020 and June 12, 2020, respectfully. The removals were due to an error in the material specification of the hinges and connecting angle components of the Series 850 Glass & Aluminum Sectional Garage doors being specified different than was tested.

If you have any questions or need additional information, please contact Helmy A. Makar, P.E., Product Control Section Supervisor at 786-315-2590.

Thank you for your attention on this matter.