




**MIAMI-DADE COUNTY, FLORIDA
HERBERT S. SAFFIR PERMITTING AND INSPECTION CENTER**

**Department of Regulatory and Economic Resources
Board and Code Administration Division**
11805 SW 26th Street (Coral Way) • Room 230
MIAMI, FLORIDA 33175-2474
(786) 315-2509 FAX (786) 315-2560
www.miamidade.gov/building

ADVISORY MEMO

TO: ALL BUILDING OFFICIALS IN MIAMI-DADE COUNTY

FROM:  **Michael L. Goolsby, Director
Board and Code Administration Division**

DATE: November 15, 2019

**SUBJECT: Polyglass USA, Inc., Polystick TU Plus and Polystick TU Max Tile Underlayments
listed under NOA# 17-0614.22**

Isolated cases of facer delamination and facer degradation of the Polyglass USA, Inc., Polystick TU Plus and Polystick TU Max Tile Underlayments, listed under NOA# 17-0614.11, have been reported in Miami-Dade County.

It is requested that all Roofing Inspectors be advised to exercise vigilance regarding this matter. Jobs where evidence of facer delamination and/or degradation is observed must be stopped and immediately reported to the Product Control Section.

Thank you for your continued cooperation in the matter. If you have any additional questions, please contact our Roofing Product Control Examiners, Mr. Alex Tigera (Alex.Tigera@miamidade.gov, 786-315-2589) or Mr. Jorge Acebo (Jorge.Acebo@miamidade.gov, 786-315-2588).

Cc: Helmy Makar, P.E. – Product Control Section Supervisor