


RECLAIMED WATER PIPING
PANTONE PURPLE 522C




NON-METALLIC PIPE


N.T.S.

2.5"-6" PIPE: 3" TAPE IS CENTERED
ALONG TOP HALF OF PIPE

TYPICAL METALLIC PIPE



8"-18" PIPE: 6" TAPE IS PLACED ALONG
BOTH SIDES OF TOP HALF OF PIPE




20" AND LARGER PIPE: TAPE IS PLACED ON BOTH
SIDES OF THE TOP HALF OF THE PIPE WITH A THIRD
STRIP CENTERED ALONG TOP HALF OF PIPE



METALLIC PIPE

N.T.S.

PURPLE ADHESIVE VINYL TAPE (TYPICAL)



PLAN VIEW

N.T.S.

NOTES:

1. PIPE IDENTIFICATION: RECLAIMED WATER MAIN OR RECLAIMED WATER LINE.
2. BURIED PIPE SHALL BE COLOR CODED WITH PURPLE TAPE 5 MILS IN THICKNESS WITH ADHESIVE BACKING.
3. TAPE SHALL RUN FROM JOINT TO JOINT ALONG THE ENTIRE LENGTH OF THE PIPE.

ITEM	CROSS REF.	SPEC. REF.



ISSUE DATE	APPROVED BY
12/16/2010	V.E.F.

STANDARD DETAIL

PIPE IDENTIFICATION

R
4.0
SHEET 1 OF 1