



**NOTES:**

1. HEIGHT OF SIGN WILL DEPEND ON LOCATION AND SURROUNDING LANDSCAPE PLANT TYPES. IN ALL CASES, THE SIGN SHALL BE CLEARLY VISIBLE TO THE PUBLIC.
2. POST SHALL BE 2 3/8" OD, SEAMLESS, EXTRUDED, SCHEDULE 80 ALUMINUM PIPE. POST SHALL BE 6061-T6 ALLOY AND CONFORM TO ASTM B429. POST SHALL HAVE A MILL FINISH.
3. MOUNTING HARDWARE SHALL BE TYPE 316 STAINLESS STEEL OR ALUMINUM.
4. SIGN POST SHALL BE PLACED BY THE CONTRACTOR IN ACCORDANCE WITH THE PLANS OR AS APPROVED BY THE DEPARTMENT. SIGN POST SHALL BE INSTALLED PLUMB AND LEVEL.
5. BACKGROUND OF SIGN SHALL BE WHITE (RECLAIMED WATER LINES SHALL BE PANTONE PURPLE 522C), BORDER AND LETTERS SHALL BE BLACK HELVETICA, SWISS 721 COREL OR APPROVED EQUAL.
6. ENGINEERING GRADE REFLECTIVE MATERIALS SHALL BE USED.
7. SIGN MATERIAL SHALL BE OF 14 GAUGE ANODIZED ALUMINUM.

SUB-AQUEOUS PIPELINE CROSSING SIGNAGE		01581
ITEM	CROSS REF.	SPEC. REF.



<u>ISSUE DATE</u>	<u>APPROVED BY</u>
01/05/2010	V.F.C.
07/20/2016	D.V.

STANDARD DETAIL

SIGN POST INSTALLATION

GS  
4.0  
SHEET 2 OF 2